

**9. STANDARDS FOR THE MANAGEMENT OF THE AQUATIC PHYSIOTHERAPY POOL**

- 1.2 The ambient temperature in the pool hall is maintained within the range 25 to 30 degrees Celsius.
- 1.4 The atmospheric humidity level is maintained within the range 50 to 60% with a preferred maximum of 60%.
- 1.6 Disinfectant levels are maintained within the following parameters:  
If disinfected using chlorine only:
- Free chlorine within the range 0.5 to 3.0 parts per million (ppm) ideally 1-2ppm
  - Total chlorine within the range 0.5 to 4.0 ppm
  - Residual chlorine is never more than 1.0 ppm and is less than half the free level.
- 1.8 The total alkalinity is maintained within the range 80 to 200 ppm.
- 1.9 The calcium hardness is maintained within the range 80 to 200 ppm.